

Another Wastewater Project Update




Utility Commission
Wausau, WI

January 8, 2019



An Aging Facility



- Phase 1 1939  80 Years Old
- Phase 2 1967  50 Years Old
- Phase 3 1988  30 Years Old

One of Wausau's Most Valuable Assets



Potential Value = \$175M*

* Based on recent new 24-mgd nutrient-removing treatment facility for Denver, CO. Grand opening 2017. Cost = \$417M. [CCI 2018 = 10,959. CCI 2011 = 9070. Cost = \$504M in \$2018. Includes a 7-mile forcemain.]

For Significant Facility Upgrades, EPA and WDNR Require a 20-Year Plan | **Facility Plan**

- Upgrade Considerations
 - Safety, Reliability, Performance
 - Capacity
 - Regulations
- Facility Plan Required for Clean Water Fund Funding

The Foremost Plan Objectives

- The Recommended Plan
 - ▶ Maximize Benefit of Existing Infrastructure
 - ▶ Maximize Return on Previous Investment



Comprehensive Condition Assessment

All Processes and Structures


Example
Phosphorus-
Removing
Chemical
Storage and
Feed System

Condition Categories	Pass	Fail
Safety, Reliability, Performance		■
Capacity		■
Regulations		■
Capacity	<p>The storage and feed capacity is adequate for the current WPDES Permit limit; however, both will be inadequate for the future phosphorus TMDL limit. Moreover, the Facility will need the ability to feed phosphorus-removing chemicals to multiple locations – e.g., upstream primary settling, upstream secondary settling, upstream filtration, and to the belt-filter press underflow.</p>	
Configuration	<ul style="list-style-type: none"> ▪ Number of Chemical Storage Tanks = 1 ▪ Number of Chemical Feed Pumps = 2 ▪ Type of Chemical Feed Pumps = diaphragm ▪ Storage Volume = 4,800 gal 	
Description	<p>The Facility uses aluminum sulfate (alum) to comply with its current 1 mg-TP/L limit. Alum is stored in a single 4,800-gal chemical storage tank and fed to the grit system upstream of primary settling. This is currently the only alum feed point. The Facility currently uses roughly 350 gpd on average.</p>	
Issues	<ul style="list-style-type: none"> ▪ The current system lacks storage volume to meet the demands of the impending phosphorus TMDL. Moreover, the Facility might be best served by feeding multiple chemicals. ▪ The existing system feeds alum to a single location. The impending phosphorus TMDL will require multiple feed locations. ▪ The chemical storage tank lacks adequate containment. This is a safety concerns. 	

Condition Assessment Summary


Alternative Compartments and Unit Processes	Safety, Reliability, Performance	Capacity	Regulations
Preliminary Treatment	■	■	
Primary Settling	■		
Activated Sludge System	■	■	
Secondary Settling	■		
Phosphorus and Filtration			■
Disinfection	■	■	
Anaerobic Digestion	■		
Solids Processing	■	■	●
Site Features	■		
Administration-Maintenance-Storage	■		

Preliminary Treatment




Alternative Compartments and Unit Processes	Safety, Reliability, Performance	Capacity	Regulations
Preliminary Treatment	■	■	
Primary Settling	■		
Activated Sludge System	■	■	
Secondary Settling	■		
Phosphorus and Filtration			■
Disinfection	■	■	
Anaerobic Digestion	■		
Solids Processing	■	■	●
Site Features	■		
Administration-Maintenance-Storage	■		

Primary Settling




Alternative Compartments and Unit Processes	Safety, Reliability, Performance	Capacity	Regulations
Preliminary Treatment	■	■	
Primary Settling	■		
Activated Sludge System	■	■	
Secondary Settling	■		
Phosphorus and Filtration			■
Disinfection	■	■	
Anaerobic Digestion	■		
Solids Processing	■	■	●
Site Features	■		
Administration-Maintenance-Storage	■		

Activated Sludge System



Alternative Compartments and Unit Processes	Safety, Reliability, Performance	Capacity	Regulations
Preliminary Treatment	■	■	
Primary Settling	■		
Activated Sludge System	■	■	
Secondary Settling	■		
Phosphorus and Filtration			■
Disinfection	■	■	
Anaerobic Digestion	■		
Solids Processing	■	■	●
Site Features	■		
Administration-Maintenance-Storage	■		

Secondary Settling



Alternative Compartments and Unit Processes	Safety, Reliability, Performance	Capacity	Regulations
Preliminary Treatment	■	■	
Primary Settling	■		
Activated Sludge System	■	■	
Secondary Settling	■		
Phosphorus and Filtration			■
Disinfection	■	■	
Anaerobic Digestion	■		
Solids Processing	■	■	●
Site Features	■		
Administration-Maintenance-Storage	■		

Phosphorus and Filtration



Alternative Compartments and Unit Processes	Safety, Reliability, Performance	Capacity	Regulations
Preliminary Treatment	■	■	
Primary Settling	■		
Activated Sludge System	■	■	
Secondary Settling	■		
Phosphorus and Filtration			■
Disinfection	■	■	
Anaerobic Digestion	■		
Solids Processing	■	■	●
Site Features	■		
Administration-Maintenance-Storage	■		

Disinfection



Alternative Compartments and Unit Processes	Safety, Reliability, Performance	Capacity	Regulations
Preliminary Treatment	■	■	
Primary Settling	■		
Activated Sludge System	■	■	
Secondary Settling	■		
Phosphorus and Filtration			■
Disinfection	■	■	
Anaerobic Digestion	■		
Solids Processing	■	■	●
Site Features	■		
Administration-Maintenance-Storage	■		

Anaerobic Digestion



Alternative Compartments and Unit Processes	Safety, Reliability, Performance	Capacity	Regulations
Preliminary Treatment	■	■	
Primary Settling	■		
Activated Sludge System	■	■	
Secondary Settling	■		
Phosphorus and Filtration			■
Disinfection	■	■	
Anaerobic Digestion	■		
Solids Processing	■	■	●
Site Features	■		
Administration-Maintenance-Storage	■		

Solids Processing



Alternative Compartments and Unit Processes	Safety, Reliability, Performance	Capacity	Regulations
Preliminary Treatment	■	■	
Primary Settling	■		
Activated Sludge System	■	■	
Secondary Settling	■		
Phosphorus and Filtration			■
Disinfection	■	■	
Anaerobic Digestion	■		
Solids Processing	■	■	●
Site Features	■		
Administration-Maintenance-Storage	■		

Site Features



Alternative Compartments and Unit Processes	Safety, Reliability, Performance	Capacity	Regulations
Preliminary Treatment	■	■	
Primary Settling	■		
Activated Sludge System	■	■	
Secondary Settling	■		
Phosphorus and Filtration			■
Disinfection	■	■	
Anaerobic Digestion	■		
Solids Processing	■	■	●
Site Features	■		
Administration-Maintenance-Storage	■		



Administration-Maintenance-Storage




Alternative Compartments and Unit Processes	Safety, Reliability, Performance	Capacity	Regulations
Preliminary Treatment	■	■	
Primary Settling	■		
Activated Sludge System	■	■	
Secondary Settling	■		
Phosphorus and Filtration			■
Disinfection	■	■	
Anaerobic Digestion	■		
Solids Processing	■	■	●
Site Features	■		
Administration-Maintenance-Storage	■		

The Issues are Pervasive




Planning-Level Costs

▶ \$80M




Planning-Level Costs

▶ \$80M



■ Plan

Schedule



- Future Phased Rate Increase
- Adopted Phased Rate Increase
- Submit Final Facility Plan

Preliminary Design Drawings


GENERAL		
1	001-G-1	COVER
2	001-G-2	INDEX TO DRAWINGS
3	001-G-3	CIVIL LEGEND AND GENERAL NOTES
4	001-G-4	GENERAL LEGEND, SYMBOLS AND ABBREVIATIONS
5	001-G-5	FLYBINS LEGEND-WAC LEGEND/ELECTRICAL LEGEND
6	001-G-6	INSTRUMENTATION AND CONTROL STANDARD LEGEND
7	001-G-7	INSTRUMENTATION AND CONTROL STANDARD SYMBOLS
SITE DEVELOPMENT		
7	002-C-1	SITE PLAN
PROCESS SUMMARY		
9	004-M-1	LIQUID TREATMENT FLOW DIAGRAM
10	004-M-2	SOLIDS TREATMENT FLOW DIAGRAM
11	004-M-3	HYDRAULIC PROFILE
12	004-M-4	HYDRAULIC PROFILE
INSTRUMENTATION AND CONTROL		
12	008-I-1	FIBER NETWORK OVERVIEW
FLOWSHEETS		
13	009-N-1	INFLUENT SCREENING
14	009-N-2	SCREENING HANDLING
15	009-N-3	RWW PUMPING
16	009-N-4	GRIT REMOVAL
17	009-N-5	GRIT HANDLING
18	009-N-6	PRIMARY INFLUENT SPLITTING
19	009-N-7	PRIMARY CLARIFICATION
20	009-N-8	RAS WAS PUMPING
21	009-N-9	RAS WAS PUMPING
22	009-N-10	AERATION BLOWERS
23	009-N-11	JUNCTION STRUCTURE AND ANOXIC SELECTOR TANK
24	009-N-12	ACTIVATED SLUDGE BASINS
25	009-N-13	SECONDARY INFLUENT SPLITTING
26	009-N-14	SECONDARY CLARIFICATION 1&2
27	009-N-15	SECONDARY CLARIFICATION 1&4
28	009-N-16	SECONDARY SCUM HANDLING
29	009-N-17	SECONDARY EFFLUENT PUMPING
30	009-N-18	FILTRATION
31	009-N-19	FILTRATION CLEANING
32	009-N-20	FILTRATION CHEMICAL FEED
33	009-N-21	FILTRATION POLYMER FEED
34	009-N-22	UV DISINFECTION
35	009-N-23	W3 EFFLUENT PUMPING
36	009-N-25	DIGESTER HEATING-RECIRC AND SLUDGE TRANSFER
37	009-N-27	DIGESTER FEED OVERFLOW MIXING
38	009-N-28	DIGESTER GAS COLLECTION AND WASTE GAS BURNER
39	009-N-29	DIGESTER GAS COMPRESSION STORAGE DISTRIBUTION
40	009-N-30	DIGESTER GAS AND NATURAL GAS BOILERS
41	009-N-31	HOT WATER DISTRIBUTION
42	009-N-33	PRIMARY SCUM PUMPING
43	009-N-34	PRIMARY SLUDGE PUMPING
44	009-N-35	PRIMARY SLUDGE SCREENING
45	009-N-36	PSD THICKENING & PUMPING
46	009-N-37	WAS THICKENING
47	009-N-38	TWAS PUMPING
48	009-N-39	GBT POLYMER FEED
49	009-N-40	SLUDGE DEWATERING
50	009-N-41	BYPOLYMER FEED
51	009-N-42	SLUDGE GATE PUMPING
52	009-N-43	DRYER DOSING PUMPS
53	009-N-44	DRYER DEPOSITOR
54	009-N-45	SLUDGE DRYING
55	009-N-46	DRYING AIR TREATMENT
56	009-N-47	DRYER BIOSOLIDS STORAGE AND HANDLING
57	009-N-48	THERMAL FLUID SYSTEM
58	009-N-49	RECYCLE PUMPING
59	009-N-50	COMPRESSED AIR SYSTEM
60	009-N-51	PERIC FEED SYSTEM

MAIN BUILDING		
61	100-R-1	REMOVAL PLAN
62	100-R-2	REMOVAL PLAN
63	100-R-3	REMOVAL PLAN
64	100-R-4	REMOVAL PLAN
65	100-R-12	REMOVAL PLAN
66	100-R-13	REMOVAL PLAN
67	100-R-14	REMOVAL PLAN
68	100-R-15	REMOVAL PLAN
69	100-R-18	REMOVAL PLAN
70	100-R-19	REMOVAL PLAN
71	100-R-20	REMOVAL PLAN
72	100-R-22	REMOVAL PLAN
73	100-R-28	REMOVAL SECTION
74	100-M-1	PLAN
75	100-M-2	PLAN
76	100-M-3	PLAN
77	100-M-4	PLAN
78	100-M-10	PLAN
79	100-M-11	PLAN
80	100-M-12	PLAN
81	100-M-13	PLAN
82	100-M-18	PLAN
83	100-M-19	PLAN
84	100-M-28	SECTION
85	100-M-29	SECTION
ADMINISTRATIVE BUILDING		
86	120-A-1	PLAN
GRIT BUILDING		
87	200-R-1	REMOVAL PLAN
88	200-R-2	REMOVAL PLAN
89	200-M-1	PLAN
90	200-M-2	PLAN
91	200-M-3	PLAN
92	200-M-4	SECTION
93	200-M-5	SECTION
PRIMARY CLARIFIERS 1-4		
94	310-R-1	REMOVAL PLAN
95	310-M-1	PLAN
96	310-M-2	PLAN
97	310-M-3	PLAN
98	310-M-4	SECTION
99	310-M-5	SECTION
ACTIVATED SLUDGE BUILDING		
100	400-R-1	REMOVAL PLAN
101	400-R-2	REMOVAL PLAN
102	400-M-1	PLAN
103	400-M-2	PLAN
104	400-M-3	SECTION
JUNCTION STRUCTURE		
105	404-M-1	PLAN
106	404-M-2	SECTION
ANOXIC SELECTOR TANK		
107	405-M-1	PLAN
108	405-M-2	PLAN
109	405-M-3	SECTION
MIXING TANK		
110	406-R-1	REMOVAL PLAN
111	406-M-1	PLAN
112	406-M-2	SECTION
ACTIVATED SLUDGE BASINS		
113	410-R-1	REMOVAL PLAN
114	410-M-1	PLAN
115	410-M-2	PLAN
116	410-M-3	SECTION
SECONDARY SPLITTER		
117	500-M-1	PLANS AND SECTION


SECONDARY CLARIFIER 1-2		
118	510-R-1	REMOVAL PLAN
119	510-M-1	PLAN
SECONDARY SCUM MARHOLE 1		
120	515-M-1	PLAN AND SECTION
SECONDARY CLARIFIER 3		
121	530-R-1	REMOVAL PLAN
122	530-M-1	PLAN
SECONDARY SCUM MARHOLE 2		
123	535-M-1	PLAN AND SECTION
SECONDARY CLARIFIER 4		
124	540-M-1	PLAN
125	540-M-2	PLAN
126	540-M-3	SECTION
EFFLUENT BUILDING		
127	600-R-1	REMOVAL PLAN
128	600-R-2	REMOVAL PLAN
129	600-R-3	REMOVAL PLAN
130	600-M-1	PLAN
131	600-M-2	PLAN
132	600-M-3	PLAN
133	600-M-4	SECTIONS
P-CHEM STORAGE BUILDING		
134	610-M-1	PLAN
135	610-M-2	PLAN
136	610-M-3	SECTIONS
DIGESTION BUILDING		
137	700-R-1	REMOVAL PLAN
138	700-R-2	REMOVAL PLAN
139	700-R-3	REMOVAL PLAN
140	700-R-4	REMOVAL PLAN
141	700-R-5	REMOVAL PLAN
142	700-R-6	REMOVAL PLAN
143	700-R-7	REMOVAL PLAN
144	700-M-1	PLAN
145	700-M-2	PLAN
146	700-M-3	PLAN
147	700-M-4	PLAN
148	700-M-5	PLAN
149	700-M-6	PLAN
150	700-M-7	PLAN
151	700-M-8	PLAN
152	700-M-9	PLAN
153	700-M-10	SECTION
154	700-M-11	SECTION
SOLIDS BUILDING		
155	770-M-1	PLAN
156	770-M-2	PLAN
157	770-M-3	PLAN
158	770-M-4	PLAN
159	770-M-5	SECTION
SILO		
160	771-M-1	PLAN AND SECTION
PSD THICKENER		
161	775-M-1	PLANS AND SECTION
TUNNELS		
162	800-R-1	REMOVAL PLANS
163	800-M-1	PLANS
TUNNEL SYSTEM NO. 2		
164	810-M-1	PLAN

Process Design and Flowsheet Drawings

PROCESS CONTROL SYSTEM HMI
[HMI-101]
(PARTIAL)



Preliminary Design Drawings




- GENERAL NOTES:**
1. CONTRACTOR TO FIELD VERIFY EXISTING CONDITIONS, DIMENSIONS, AND ELEVATIONS PRIOR TO CONSTRUCTION AND/OR FABRICATION.
 2. REFER TO 001 SERIES OF DRAWINGS FOR THE SPACE ENVIRONMENT/HAZARDOUS RATING SCHEDULE REGARDING ENVIRONMENTAL CONDITIONS ANTICIPATED WITHIN EACH SPACE AND ALLOWABLE MATERIALS OF CONSTRUCTION TO BE USED WITHIN EACH SPACE.
 3. HAZARDOUS RATINGS IDENTIFIED ON THIS DRAWING INDICATE SPACES IN WHICH A HAZARDOUS ENVIRONMENT MAY GENERALLY EXIST. CONTRACTOR SHALL REFER TO SPACE ENVIRONMENT/HAZARDOUS RATING SCHEDULE IN 001 SERIES OF DRAWINGS FOR ADDITIONAL INFORMATION EXPLAINING THE EXTENT AND ENVELOPE ASSOCIATED WITH THESE HAZARDS.

OVERALL GRADE PLAN
 0' 1" = 1'

- DESIGNER NOTES:**
1. GBTs 7,000 LBS DRY, 11,000 LBS LOADED.
 2. BFFs 17,400 LBS DRY, 10,300 LBS LOADED.
 3. DRYER 20,000 LBS HEAVIEST SHIPMENT, 105,000 LBS OPERATING.
 4. DOSING RUMPS 220 LBS.
 5. PROVIDE STRIP CURTAINS AROUND BELT FILTER PRESSES FOR HYDROGEN SULFIDE CONTAINMENT.

Preliminary Design Site Plan





Preliminary Design Site Plan | New Structures




Planning-Level and Preliminary Design Costs

▶ \$80M




Planning-Level and Preliminary Design Costs


▶ **\$80M**




Typical Monthly Residential User Rates



Comparison of Future Monthly Residential Wastewater Bills [37 kgpy]



Project Schedule



▽	Future Phased Rate Increase
▼	Adopted Phased Rate Increase
▼	Submit Final Facility Plan

Action Items

- City Approve Facility Plan in January 2018
- Submit Facility Plan to WDNR in January 2019
- Proceed with Final Design in January/February 2019
- Submit Reviewable Plans and Specifications to WDNR by Sep 30, 2019

Questions and Discussion




Thank You


Backup Materials





Simple Unit Process Capacity Analysis





Costs by High-Level WWTF Function





Historical Flows




Historical BOD Loadings




Historical TSS Loading




Historical TKN Loading




Historical TP Loading




Effluent WLA BOD Limit




TMDL Phosphorus Limit




Historical Effluent BOD




Historical Effluent BOD and Minimum WLA Limit



Historical Effluent TP



Historical Effluent Fecal Coliform



Historical Effluent pH




Future Design Values


Flow	Flow (mgd)	Peaking Factor
Average	5.4	
Maximum Month	9.2	1.69
Maximum Week	11.6	2.14
Maximum Day	16.8	3.10
Peak Hour	22.0	4.06
Peak Instantaneous	35.8	

Parameter	AA (ppd)	MM (ppd)	MW (ppd)	MD (ppd)
BOD	11,190	14,438	17,458	24,108
TSS	11,763	16,361	19,005	31,445
TKN	2,004	2,586	3,130	4,193
TP	545	703	850	1,258



Activated Sludge System Configuration




Low-Level Phosphorus and WLA BOD Compliance




Cloth-Media Filters



Low-Level Phosphorus and WLA BOD Compliance



Medium-Temperature Belt Dryer




**Class A EQ
Biosolids Product**





Solids Processing Economic Analysis

Scenarios	A	B	C	D	E	F	G	H
	SOL-1 Free Distribution	SOL-1 0% City 100% Landfill	SOL-2 100% City 0% Landfill	SOL-2 50% City 50% Landfill	SOL-2 0% City 100% Landfill	SOL-3 100% City 0% Landfill	SOL-3 50% City 50% Landfill	SOL-3 0% City 100% Landfill
Annual Costs								
Electricity	\$40,000	\$40,000	\$0	\$0	\$0	\$0	\$0	\$0
Heat	\$135,000	\$135,000	\$0	\$0	\$0	\$0	\$0	\$0
City Disposal	\$0	\$0	\$150,000	\$75,000	\$0	\$150,000	\$75,000	\$0
Landfill Tip	\$0	\$91,000	\$0	\$209,000	\$418,000	\$0	\$209,000	\$418,000
Landfill Haul	\$0	\$45,000	\$0	\$57,000	\$114,000	\$0	\$57,000	\$114,000
Total	\$175,000	\$311,000	\$150,000	\$341,000	\$532,000	\$150,000	\$341,000	\$532,000
20-Year Present Worth Cost								
Annual	\$2,459,000	\$4,370,000	\$2,108,000	\$4,792,000	\$7,476,000	\$2,108,000	\$4,792,000	\$7,476,000
Capital	\$22,528,000	\$22,528,000	\$19,043,000	\$19,043,000	\$19,043,000	\$17,027,000	\$17,027,000	\$17,027,000
Total	\$24,987,000	\$26,898,000	\$21,151,000	\$23,835,000	\$26,519,000	\$19,135,000	\$21,819,000	\$24,503,000
Monthly Residential Cost								
Capital	\$3.42	\$3.42	\$2.89	\$2.89	\$2.89	\$2.59	\$2.59	\$2.59
Annual	\$0.53	\$0.95	\$0.46	\$1.04	\$1.63	\$0.46	\$1.04	\$1.63
Total	\$3.96	\$4.37	\$3.35	\$3.94	\$4.52	\$3.05	\$3.63	\$4.21



Solids Processing User Costs





480V POWER PANELS
(60" WALL SPACE)

120V LIGHTING PANELS
(60" WALL SPACE)

FLOOR MOUNTED
TRANSFORMER

BOILER

BOILER PUMPS

HEATING PUMPS

WATER SERVICE

FLOOR MOUNTED
UPS BATTERIES &
CONTROLLER
(FOR LAB LIGHTING
PANEL)


120V LIGHTING PANEL
(30" WALL SPACE)

TRANSFORMER
MOUNTED ABOVE
PANEL

120V LAB LIGHTING
PANEL (FLUSH MOUNTED)

GRADE PLAN






- GENERAL NOTES:**
1. CONTRACTOR TO FIELD VERIFY EXISTING CONDITIONS, DIMENSIONS, AND ELEVATIONS PRIOR TO CONSTRUCTION AND/OR FABRICATION.
 2. REFER TO 001 SERIES OF DRAWINGS FOR THE SPACE ENVIRONMENT/HAZARDOUS RATING SCHEDULE REGARDING ENVIRONMENTAL CONDITIONS ANTICIPATED WITHIN EACH SPACE AND ALLOWABLE MATERIALS OF CONSTRUCTION TO BE USED WITHIN EACH SPACE.
 3. HAZARDOUS RATINGS IDENTIFIED ON THIS DRAWING INDICATE SPACES IN WHICH A HAZARDOUS ENVIRONMENT MAY GENERALLY EXIST. CONTRACTOR SHALL REFER TO SPACE ENVIRONMENT/HAZARDOUS RATING SCHEDULE IN 001 SERIES OF DRAWINGS FOR ADDITIONAL INFORMATION EXPLAINING THE EXTENT AND ENVELOPE ASSOCIATED WITH THESE HAZARDS.


- DESIGNER NOTES:**
1. GAS HANDLING ROOM HVAC:
COMBUSTIBLE GAS DETECTION
CONTINUOUS VENTILATION AT 12 AHHR
 2. COOLING WATER TO EACH COMPRESSOR.
 3. EQUIPMENT WEIGHT:
COMPRESSOR: 3,000 LBS + MOTOR

PARTIAL GRADE PLAN




KEY PLAN

Schedule




- ▽ Future Phased Rate Increase
- ▼ Adopted Phased Rate Increase
- ▼ Submit Final Facility Plan


Primary Revenue Sources for Wausau Wastewater Utility




The Structure of a Residential Wastewater Bill



Comparison of Current Monthly Residential Wastewater Bills [37.4 kgpy]



Cost Opinion Accuracy



Opportunity to Influence Cost

